

SS 2 - EMERGENCY WARNING SYSTEMS

Address:			
Provided by (name):			
Make (if known):		Type: 2	
Model (if known):		□ 3	
Response:	Manual	□ 4	
	☐ Automatic	□ 5	
Supplementary Devices:	Heat Detectors	□ 6	
	☐ Smoke Detectors	□ ₇	
Alarm Interfacing Eg SS9, SS3/			
Performance/Installation Stan	NZS 4512 Year AS 1851 Year Specifically Designed Alternate and Other (historical)	 Solution	
Inspections & Maintenance St	AS 1851 Year Specifically designed solution p	rovide details separately	
As a minimum these inspectio maintenance procedures will carried out:	be carried out in accordance with the	Planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required.	
Inspection frequency and responsibility:	│	Owner QP	
	│	Owner QP	
	│	Owner QP	
	│)wner QP	
Reporting:	repairs undertaken in the previous 24 kept with the compliance schedule an • Details of any inspection, test carried out. Include dates, wor remedies applied, and the person versions of training for owner inspections.	 The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include: Details of any inspection, test or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work. Register of training for owner inspections A Form 12A provided by an IQP annually 	

The information above is used to help generate the compliance schedule. If you are unsure of how to fill in this form please consult an IQP who is registered for the system above.